

ANALYTICAL REPORT

Montana Environmental Laboratory LLC

1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900

Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Chad Wambach
Meadow Lake Water & Sewer
394 1st Ave. WN
Kalispell, MT 59901

PWS ID: 00914

Project: L & C

Client Sample ID: - 240 Meadow Lake Dr.

Matrix: DRINKING WATER

Collected: 08/16/2019 5:00

Lab ID: 1908689-01

Received: 08/19/2019 8:30

<u>Lead & Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.07	mg/L	0.01	1.3	E200.8		08/21/2019 11:20	BLW
Lead	0.001	mg/L	0.001	0.015	E200.8		08/21/2019 11:20	BLW

Client Sample ID: - 250 Meadow Lake Dr.

Matrix: DRINKING WATER

Collected: 08/16/2019 6:15

Lab ID: 1908689-02

Received: 08/19/2019 8:30

<u>Lead & Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.06	mg/L	0.01	1.3	E200.8		08/21/2019 11:20	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		08/21/2019 11:20	BLW

Client Sample ID: - 280 Meadow Lake Dr.

Matrix: DRINKING WATER

Collected: 08/16/2019 5:00

Lab ID: 1908689-03

Received: 08/19/2019 8:30

<u>Lead & Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.05	mg/L	0.01	1.3	E200.8		08/21/2019 11:20	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		08/21/2019 11:20	BLW

Client Sample ID: - 385 Meadow Lake Dr.

Matrix: DRINKING WATER

Collected: 08/16/2019 6:00

Lab ID: 1908689-04

Received: 08/19/2019 8:30

<u>Lead & Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.10	mg/L	0.01	1.3	E200.8		08/21/2019 11:20	BLW
Lead	0.002	mg/L	0.001	0.015	E200.8		08/21/2019 11:20	BLW

Client Sample ID: - 1000 St. Andrews

Matrix: DRINKING WATER

Collected: 08/16/2019 6:00


Lab ID: 1908689-05

Received: 08/19/2019 8:30

<u>Lead & Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.07	mg/L	0.01	1.3	E200.8		08/21/2019 11:20	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		08/21/2019 11:20	BLW

MCL = Maximum Contaminant Limit ND = Not Detected
RL = Reporting Limit

MEL REVIEW: JMC



ANALYTICAL REPORT

Montana Environmental Laboratory LLC
1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900
Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Chad Wambach
Meadow Lake Water & Sewer
394 1st Ave. WN
Kalispell, MT 59901

PWS ID: 00914
Project: L & C

Client Sample ID: 90th Percentile
Matrix: DRINKING WATER

Collected:

Lab ID: 1908689-06
Received:

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper, 90th Percentile	0.09	mg/L	0.01	1.3	Calculation		08/22/2019 12:48	BLW
Lead, 90th Percentile	0.002	mg/L	0.001	0.015	Calculation		08/22/2019 12:48	BLW