



ANALYTICAL REPORT

Montana Environmental Laboratory LLC

1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900

Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Marc Liechti
APEC - Meadow Lake Water
75 Somers Rd.
Somers, MT 59932

PWS ID: 00914
Project: IOC's

Client Sample ID: WL002, EP502

Matrix: DRINKING WATER

Collected: 09/20/2022 8:00

Lab ID: 2210248-01

Received: 09/20/2022 13:15

<u>IOCs phase II & V</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Antimony	ND	mg/L	0.001	0.006	E200.8		09/22/2022 9:03	BLW
Arsenic	ND	mg/L	0.001	0.010	E200.8		09/22/2022 9:03	BLW
Barium	0.17	mg/L	0.01	2	E200.8		09/22/2022 9:03	BLW
Beryllium	ND	mg/L	0.001	0.004	E200.8		09/22/2022 9:03	BLW
Cadmium	ND	mg/L	0.001	0.005	E200.8		09/22/2022 9:03	BLW
Chromium	ND	mg/L	0.001	0.1	E200.8		09/22/2022 9:03	BLW
Fluoride	0.12	mg/L	0.01	4	E300.0		09/27/2022 10:35	BLW
Mercury	ND	mg/L	0.0001	0.002	E200.8		09/22/2022 9:03	BLW
Nickel	ND	mg/L	0.001	1	E200.8		09/22/2022 9:03	JLB
Nitrate	0.20	mg/L	0.01	10	E353.2		09/27/2022 10:35	BLW
Nitrate + Nitrite, Total	0.20	mg/L	0.01	10	E353.2		09/27/2022 10:35	BLW
Nitrite	ND	mg/L	0.01	1	E353.2		09/27/2022 10:35	BLW
Selenium	ND	mg/L	0.001	0.05	E200.8		09/22/2022 9:03	BLW
Sulfate	2.5	mg/L	0.1	500	E300.0		09/27/2022 10:35	BLW
Thallium	ND	mg/L	0.0005	0.002	E200.8		09/22/2022 9:03	BLW



ANALYTICAL REPORT

Montana Environmental Laboratory LLC

1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900

Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Marc Liechti
APEC - Meadow Lake Water
75 Somers Rd.
Somers, MT 59932

PWS ID: 00914

Project: IOC's

Client Sample ID: WL003, EP503

Matrix: DRINKING WATER

Collected: 09/20/2022 8:30

Lab ID: 2210248-02

Received: 09/20/2022 13:15

IOCs phase II & V

	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Antimony	ND	mg/L	0.001	0.006	E200.8		09/22/2022 9:03	BLW
Arsenic	ND	mg/L	0.001	0.010	E200.8		09/22/2022 9:03	BLW
Barium	0.15	mg/L	0.01	2	E200.8		09/22/2022 9:03	BLW
Beryllium	ND	mg/L	0.001	0.004	E200.8		09/22/2022 9:03	BLW
Cadmium	ND	mg/L	0.001	0.005	E200.8		09/22/2022 9:03	BLW
Chromium	ND	mg/L	0.001	0.1	E200.8		09/22/2022 9:03	BLW
Fluoride	0.10	mg/L	0.01	4	E300.0		09/27/2022 10:35	BLW
Mercury	ND	mg/L	0.0001	0.002	E200.8		09/22/2022 9:03	BLW
Nickel	ND	mg/L	0.001	1	E200.8		09/22/2022 9:03	JLB
Nitrate	0.22	mg/L	0.01	10	E353.2		09/27/2022 10:35	BLW
Nitrate + Nitrite, Total	0.22	mg/L	0.01	10	E353.2		09/27/2022 10:35	BLW
Nitrite	ND	mg/L	0.01	1	E353.2		09/27/2022 10:35	BLW
Selenium	ND	mg/L	0.001	0.05	E200.8		09/22/2022 9:03	BLW
Sulfate	2.4	mg/L	0.1	500	E300.0		09/27/2022 10:35	BLW
Thallium	ND	mg/L	0.0005	0.002	E200.8		09/22/2022 9:03	BLW