



# ANALYTICAL REPORT

Montana Environmental Laboratory LLC  
1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900  
Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Marc Liechti  
APEC - Meadow Lake Water  
75 Somers Rd.  
Somers, MT 59932

PWS ID: 00914  
Project: Lead & Copper

**Client Sample ID:** - 1275 Oakmont Ln **Lab ID:** 2210641-01  
**Matrix:** DRINKING WATER **Collected:** 09/29/2022 5:30 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.02	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW

**Client Sample ID:** - 1293 Oakmont Ln **Lab ID:** 2210641-02  
**Matrix:** DRINKING WATER **Collected:** 09/29/2022 7:50 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.02	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW

**Client Sample ID:** - 381 Gleneagles Ln **Lab ID:** 2210641-03  
**Matrix:** DRINKING WATER **Collected:** 09/29/2022 7:00 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.05	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW

**Client Sample ID:** - 131 Gleneagles Trl **Lab ID:** 2210641-04  
**Matrix:** DRINKING WATER **Collected:** 09/28/2022 11:20 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.08	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	0.004	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW

**Client Sample ID:** - 345 Meadowlake Dr **Lab ID:** 2210641-05  
**Matrix:** DRINKING WATER **Collected:** 09/27/2022 13:03 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	ND	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW



# ANALYTICAL REPORT

## Montana Environmental Laboratory LLC

1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900

Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Marc Liechti  
APEC - Meadow Lake Water  
75 Somers Rd.  
Somers, MT 59932

PWS ID: 00914  
Project: Lead & Copper

**Client Sample ID:** - 315 Meadowlake Dr **Lab ID:** 2210641-06  
**Matrix:** DRINKING WATER **Collected:** 09/29/2022 7:30 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.07	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW

**Client Sample ID:** - 240 Meadowlake Dr **Lab ID:** 2210641-07  
**Matrix:** DRINKING WATER **Collected:** 09/29/2022 7:00 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.08	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	0.002	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW

**Client Sample ID:** - 285 Golf Course Dr **Lab ID:** 2210641-08  
**Matrix:** DRINKING WATER **Collected:** 09/29/2022 8:00 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.01	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW

**Client Sample ID:** - 345 Golf Course Dr **Lab ID:** 2210641-09  
**Matrix:** DRINKING WATER **Collected:** 09/28/2022 13:03 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.01	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW

**Client Sample ID:** - 385 Golf Course Dr **Lab ID:** 2210641-10  
**Matrix:** DRINKING WATER **Collected:** 09/29/2022 6:00 **Received:** 09/29/2022 12:15

<u>Lead &amp; Copper</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper	0.09	mg/L	0.01	1.3	E200.8		10/05/2022 9:15	BLW
Lead	ND	mg/L	0.001	0.015	E200.8		10/05/2022 9:15	BLW



# ANALYTICAL REPORT

## Montana Environmental Laboratory LLC

1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900

Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Marc Liechti  
APEC - Meadow Lake Water  
75 Somers Rd.  
Somers, MT 59932

PWS ID: 00914  
Project: Lead & Copper

**Client Sample ID:** 90th Percentile

**Matrix:** DRINKING WATER

**Collected:**

**Lab ID:** 2210641-11

**Received:** 09/29/2022 12:15

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Copper, 90th Percentile	<b>0.08</b>	mg/L	0.01	1.3	Calculation		10/06/2022 10:37	BLW
Lead, 90th Percentile	<b>0.002</b>	mg/L	0.001	0.015	Calculation		10/06/2022 10:37	BLW

